

QUERIES/QUESTIONS RAISED FROM SITE VISIT/PRETENDER CONFERENCE FOR TENDER NO. EACC/T/24/2021-022 AND EACC/T/25/2021-2022 HELD ON 19th April 2022

No	Tender No	Query/Question	Response
1	EACC/T/25/2021-2022	Who will supply the permanent power cable for installation of the lift? Is it Main Contractor or nominated Lift sub-Contractor	Electrical Subcontractor under the Main Works Contractor
2	EACC/T/25/2021-2022	Will the Client pay advance payment for the import component against advance payment guarantee or bond?	There shall be no advance payment
3	EACC/T/25/2021-2022	Requirement for provision of similar experience (scenic lifts) is it a must	No. Kindly refer to the evaluation criteria in the tender document.
4	EACC/T/25/2021-2022	Do foreign firms require NCA registration in order to bid	No, Foreign firms do not require NCA registration to bid.
5	EACC/T/25/2021-2022	Overhead of the lift (Height) This aspect should be included	The lift shaft provisions will be so as to accommodate any type of machine roomless lift whereby the top floor will have a slightly higher height than the rest. The lift shaft will be built by the main contractor.
6	Both	Assistance for upload of documents in IFMIS	Kindly refer to the tender document